PANAMA CANAL AUTHORITY		VARIATION	PAGE 1 OF 2
1. REQUEST FOR PROPOSAL No.:		2. CONTRACT No.:	3. DATE: October 18 , 2011
RFP-76161	CMC-221427	4. VARIATION No.: 019	
5. ISSUED BY: PANAMA CANAL AUTHORITY Employer's Representative Locks Project Management Division Building 740, Corozal Panama, Republic of Panama 6. NAME AND ADDRESS OF CONTRACTOR (1)		7. CONTRACTOR'S TELEPHONE N	UMBER:
PHYSICAL & POSTAL ADDRESS) Grupo Unidos por el Canal, S.A. Building 22B, Brujas Road Cocoli, Republic of Panama		507-316-9900 8. CONTRACTOR'S FACSIMILE NUMBER:	
9 B. THE CONTRACT REFERRED 1 (such as the paying office, acco	O ON THE B N ITEM 10 I	igned, of this Variation to the Employer's ASIS OF: (Specify the legal authority). SHEREBY INCORPORATED AND MA NO. 2, IS VARIED TO INCORPORATE	S Representative/Contracting Officer. DE A PART OF THE CONTRACT. ADMINISTRATIVE CHANGES
X NO. 2 OF THIS FORM, ON THE Clause 1.16 [Entire Agreement], 4 th 9 D. OTHER. (Specify manner and the	Paragraph	(Specify the legal authority) Volume lority).	II, Conditions of Contract , Sub-
9 E. ACCOUNT NUMBER (If required		ce with the order of the Contract. If add	ilional space is required, use blank
sheets).	S	ee attached	
Except for the variation(s) herein specified, a	-		main unchanged.
11. NAME AND TITLE OF THE PERSON AUTH TO SIGN (Type or print)	Acres and the second	12. NAME AND TITLE OF THE EMPL REPRESENTATIVE/CONTRACTI	OYER'S
Bernardo González Contractor's Representative		Jorge de la Guardia, Employer's Representative	
13. CONTRACTOR Lust	14. DATE:	15. PANAMA CANAL AUTHORITY	16. DATE:
(Authorized signature)		(Employer's Representative/Contraction	ng Officer's signature)

25/10/2011

This Variation No. 19 is issued to incorporate the following:

1. In terms of RFV 0082 dated July 29, 2011, the following modification is introduced to Volume II, Part 1, of Section 03 30 00 [Concrete] of the Employer's Requirements.

Paragraph 1.04 A. 7.c. which currently reads as follows:

"c. Concrete shrinkage shall be tested in accordance with ASTM C 157, except that air storage shall commence at the age of 7 days and test specimens shall be stored in the drying room for 28 days. The average shrinkage of three test specimens after 28 days of air storage shall not exceed 0.042 percent relative to the initial comparator reading."

Shall be deleted and replaced with the following text:

- "c. Concrete shrinkage shall be tested in accordance with ASTM C 157. The average shrinkage of three test specimens after 28 days of air storage shall not exceed 0.050 percent relative to the initial comparator reading."
- There is no time or cost impact to the Locks Contract as a consequence of RFV 0082.

